

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

**LISTING No.** 3240-1483:126 Page 1 of 1

**CATEGORY:** Duct Smoke Detector Housing/Base

**LISTEE:** Mirtone, 90 Fieldstone Ct., Cheshire, CT 06410  
Contact: Brad Miller (888) 649-9827 FAX (203) 699-3108

**DESIGN:** Models 73401A, GSA-DH, and \*6260A-CU Duct Smoke Detector Units. Units consist of a metal enclosure, relay, electrical components, a separately listed open area detector, a detector base and a sampling and exhaust tubes. Refer to listee's data sheet for additional detailed product description and operational considerations.

**RATING:** The air velocity is ranging from 300-4000 fpm for Model GSA-DH and from 400-4000 fpm for Model 73401A. Model GSA-DH with Model GSA-IPHS detector head, the sensitivity must be set at Levels 1 through 4 for velocities over 1000 fpm.

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model number, electrical rating, and UL label.

**APPROVAL:** Listed as duct smoke detector housing units for use with separately listed compatible fire alarm control units. Refer to listee's Installation Instruction Manual for details.

**XLF:** \*3240-1591:108 Formerly 3240-1388:104

\*Rev. 03-16-04



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

**JUNE 22, 2004**

*Listing Expires **June 30, 2005***

Authorized By:

**DIANE K. AREND**, Senior Deputy  
Program Manager